



ਦਫਤਰ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ
ਨੰ: 1 ਫਰੀਦਕੋਟ, ਜ਼ਿਲਾ ਫਰੀਦਕੋਟ - 151203
email. sdesub1@gmail.com

ਵੱਲ

WEST POINT SCHOOL,
SANDHWAN DANE WALA ROAD. KKP.

ਨੰ: 98

ਮਿਤੀ: 07-02-2025

ਵਿਸ਼ਾ:- ਵਾਟਰ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਬਾਰੇ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਸੰਬੰਧੀ ਇਸ ਦਫਤਰ ਵੱਲੋਂ ਆਪ ਦੇ ਸਕੂਲ ਦਾ ਵਾਟਰ ਸੈਪਲ ਲਿਆ ਗਿਆ (ਰਿਪੋਰਟ ਨਾਲ ਨੱਥੀ ਹੈ) ਜੋ ਕਿ ਸਾਫ ਸੁਥਰਾ ਅਤੇ ਪੀਣ ਯੋਗ ਪਾਇਆ ਗਿਆ ਹੈ। ਇਸ ਤੋਂ ਇਲਾਵਾ ਆਪ ਦੇ ਸਕੂਲ ਦਾ ਸੈਨੀਟੇਸ਼ਨ ਵੀ ਚੈਕ ਕੀਤਾ ਗਿਆ ਜੋ ਕਿ ਸਾਫ ਸੁਥਰਾ ਅਤੇ ਵਧੀਆ ਪਾਇਆ ਗਿਆ। ਉਕਤ ਦੇ ਅਧਾਰ ਤੇ ਆਪ ਨੂੰ ਇਹ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ।

ਨੱਥੀ/ਵਾਟਰ ਟੈਸਟਿੰਗ ਰਿਪੋਰਟ ਦੀ ਕਾਪੀ

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,
ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਨੰ:1,
ਫਰੀਦਕੋਟ।

DISTRICT WATER TESTING LABORATORY, FARIDKOT

Department of water supply and sanitation, Ghanaiya Chowk, Opposite Khalsa sr. sec. school, Faridkot
dwtlfdk@gmail.com

To,

WEST POINT SCHOOL ,SANDHWANDANE WALA ROAD ,KOTKAPURA ,FARIDKOT
WEST POINT SCHOOL ,SANDHWANDANE WALA ROAD ,KOTKAPURA ,FARIDKOT


No.: DWTL/FDK/2425/00291 Dated : 30/01/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. W.P .462 Dated: 22/01/2025

As per above cited subject and reference, Please find enclosed here with the report of 2 Water sample/s received on dated 22/01/2025. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Faridkot

D/A : Test Report



Authorized Signatory
For, District water Testing Laboratory
Faridkot

DISTRICT WATER TESTING LABORATORY, FARIDKOT

Department of water supply and sanitation, Ghanaia Chowk, Opposite Khalsa sr. sec. school, Faridkot
dwtlfdk@gmail.com



TC-13893

TEST REPORT

Name & Address of Customer : WEST POINT SCHOOL ,SANDHWANDANE WALA ROAD ,KOTKAPURA ,FARIDKOT WEST POINT SCHOOL ,SANDHWANDANE WALA ROAD ,KOTKAPURA ,FARIDKOT			Customer Reference No.		No : W.P .462 Dated : 22/01/2025	
			Sample Submitted by		RANJIT SINGH	
			Date of Sample Receipt		22/01/2025	
			Analysis Starting Date		23/01/2025	
			Analysis completion Date		24/01/2025	
Discipline : Chemical Testing			Group: Water			
ULR No.:	TC103942500000053F		Sample Type :		Treated Water	
Test Report No.:	DWTL/FDK/2425/00291		Date of Issue :		30/01/2025	
Registration no.:	DWTL/FDK/REG2425/00849		Condition of Sample :		Sealed	
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		1000 ml / Plastic Bottles	
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :		WEST POINT SCHOOL ,SANDHWANDANE WALA ROAD ,KOTKAPURA ,FARIDKOT, NEAR VICE PRINCIPAL / NA	
Village :	Not Mentioned		Habitation :		Not Mentioned	
Block:	Kot Kupura		District :		Faridkot	
Latitude :	Not Mentioned		Longitude:		Not Mentioned	

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.75	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	160	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	32	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	112	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	20.8	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	14.5	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	44	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Manju Saini

Mrs. Manju
Quality Manager
Authorized Signatory
For, District water Testing Laboratory

DISTRICT WATER TESTING LABORATORY, FARIDKOT

Department of water supply and sanitation, Ghanaiya Chownk, Opposite Khalsa sr. sec. school, Faridkot
dwtlfdk@gmail.com



TEST REPORT

Name & Address of Customer : WEST POINT SCHOOL ,SANDHWANDANE WALA ROAD ,KOTKAPURA ,FARIDKOT WEST POINT SCHOOL ,SANDHWANDANE WALA ROAD ,KOTKAPURA ,FARIDKOT		Customer Reference No.	No : W.P .462 Dated : 22/01/2025
		Sample Submitted by	RANJIT SINGH
		Date of Sample Receipt	22/01/2025
		Analysis Starting Date	23/01/2025
		Analysis completion Date	24/01/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC103942500000053F	Sample Type :	Treated Water
Test Report No.:	DWTL/FDK/2425/00291	Date of Issue :	30/01/2025
Registration no.:	DWTL/FDK/REG2425/00850	Condition of Sample :	Sealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	WEST POINT SCHOOL ,SANDHWANDANE WALA ROAD ,KOTKAPURA ,FARIDKOT ,NEAR RAMP / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Kot Kupura	District :	Faridkot
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.60	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	150	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	44	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	80	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	19.2	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	7.77	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	60	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Manju Saini

Mrs. Manju
Quality Manager
Authorized Signatory
For, District water Testing Laboratory
Faridkot